

## APPENDIX F

### DESIGN EXAMPLES—NONBUILDING STRUCTURES

**F-1. Introduction.** The design examples in this appendix are to illustrate principles, factors, and concepts involved in seismic design. These are not mandatory; and other equivalent methods, materials, or details complying with this manual and applicable agency guide specifications may be used.

#### F-2. Design Examples—

<i>Fig. No.</i>	<i>Description of Design Examples</i>
F-1	<i>Elevated Tank (Braced Frame).</i> Four-legged, diagonal braced tower.
F-2	<i>Vertical Tank (On Ground).</i> Vertical water tank supported directly by the ground.
F-3	<i>Horizontal Tank (On Ground).</i> Typical horizontal tank supported on saddles.
F-4	<i>Pole-Mounted Transformer.</i> Equipment supported by a non-building pole structure.
F-5	<i>Tower-Mounted Equipment.</i> Tower-supported equipment is investigated for lateral seismic loads. The tower period is computed.

#### DESIGN EXAMPLE: F-1


##### ELEVATED TANK (BRACED FRAME):

**Description of Structure.** A 90,000 gallon steel water tank on top of a 114.5 foot high steel braced frame.

##### Lateral Loads.

$$\begin{aligned}
 & \text{where } V = (ZIC/R_w) W && \text{(SEAOC EQ 1-1)} \\
 & Z = 0.3 \text{ (Zone 3)} \\
 & I = 1.0 \\
 & R_w = 3 \text{ (SEAOC TABLE 1-1)} \\
 & S = 1.5 \text{ (Soil type } S_3, \text{ SEAOC TABLE 1-B)} \\
 & T = 1.37 \text{ (See Sheet 2)} \\
 & C = 1.25 S/T^{2/3} = 1.52 \\
 & V = (0.3 \times 1.0 \times 1.52/3) W = 0.15 W \\
 & \text{MINIMUM } C/R_w = 0.50, \quad V = 0.15W && \text{(SEAOC 1I 5a)}
 \end{aligned}$$

*Figure F-1. Elevated tank (braced frame).*



DEFLECTION  $\Delta^*$

MEMBER	LENGTH	AREA	U	U <sup>2</sup> L/A
AB	36.0	$\infty$	0	0
AD	57.5	3.0	1.134	4.30
AC	47.8	24.0	1.283	3.27
BD	47.8	24.0	-1.678	5.60
CD	28.4	8.0	-.296	.31
CF	45.3	3.5	1.598	4.62
CE	37.7	24.0	1.787	.97
DF	37.7	24.0	-1.283	2.58
EF	22.4	8.0	-.374	.39
EH	35.8	4.0	1.758	5.14
EG	29.7	24.0	1.156	.03
FH	29.7	24.0	-.787	.77
GH	17.68	$\infty$	0	0
				27.98

90,000 GALLON WATER TANK

WEIGHT OF WATER 750<sup>K</sup>  
STEEL TANK (EST) 72

WATER + TANK 822<sup>K</sup> = W

NEGLECT WT. OF TOWER

ASSUME BRACES CARRY TENSION ONLY.

COMPUTE THE PERIOD OF THE STRUCTURE TO DETERMINE COEFFICIENTS C AND S

$$T = 0.32 \sqrt{\frac{W}{K}} \quad (\text{EQ 12-1})$$

W = 822<sup>K</sup>

K = SPRING CONSTANT (KIPS/INCH)

IF A 1.0<sup>K</sup> LATERAL LOAD IS APPLIED AT THE TANK C.G.,

$$K = \frac{1.0}{\Delta}$$

WHERE  $\Delta$  = LATERAL DEFLECTION OF TANK DUE TO 1<sup>K</sup> LOAD.

$$T = 0.32 \sqrt{W \times \Delta}$$

$$\Delta = \frac{2 \times 27.98 \times 12}{30,000} = 0.0224 \text{ IN}$$

FOR 1<sup>K</sup> LOAD ON TOWER (0.5<sup>K</sup> EACH SIDE)

$$T = 0.32 \sqrt{822 \times 0.0224} = 1.37 \text{ SEC}$$

\* 0.5<sup>K</sup> APPLIED TO EACH SIDE OF TOWER. FOR 1.0<sup>K</sup> ON THE WHOLE TOWER:

$$\Sigma \frac{U^2 L}{A} = 2 \times 27.98$$

$$\Delta = \Sigma \frac{U^2 L}{AE} \text{ IN/KIP}$$

Figure F-1. Continued.

$$V = 0.15 W \text{ (SHEET 1 OF 3)}$$

$$= 0.15 \times 822 = 123.3 \text{ KIPS.}$$

**STRESS IN MEMBERS FOR LOAD APPLIED PARALLEL TO MAJOR AXIS.  $V=123.3^k$**

MEMBER	DIRECT LOAD	ECCEN. LOAD	TOTAL	UNIT
	STRESS	STRESS	STRESS	STRESS
AB	$+134 = 123.3^k$	$+16.5^k$	$+17.3^k$	—
AD	$+474$	$+2.9$	$+61.4$	$20.5^k/in^2$
AC	$+1283$	$+158.2$	$+158.2$	6.6
BD	$-1678$	$0.$	$-207$	8.63
CD	$-296$	$-1.8$	$-38.3$	4.79
CF	$+598$	$+3.7$	$+77.4$	22.1
CE	$+787$	$0.$	$+97.1$	4.05
DF	$-1283$	$0.$	$-158.2$	6.6
EF	$-374$	$-2.3$	$-48.5$	6.06
EH	$+758$	$+4.7$	$+98.1$	24.5
EG	$+156$	$0.$	$+19.2$	0.80
FH	$-787$	$0.$	$-97.1$	4.05
GH	$-487$	$-3.0$	$-63.1$	—

**STRESSES DUE TO 5% ECCENTRICITY**

$$M_e = .05 \times 36 \times 123.3 = 222^k$$

$$\text{SHEAR ON EA. OF 4 SIDES} = \frac{222}{4 \times 8} = 3.08^k$$

$$\text{STRESS IN WEB MEMBERS} = \frac{3.08}{(123.3/2)} \times (\text{DIRECT LOAD STRESS})$$

$$\text{STRESS IN COLUMNS} = 0$$

**CHECK COLUMN FORCES AND UPLIFT FOR LOAD APPLIED AT  $45^\circ$  TO MAJOR AXIS OF TOWER**

$$P = \frac{123.3 \times 120}{1.414 \times 36} \times 1.007 = \pm 293 \text{ KIPS}$$

$$(\text{NOTE: FORCE IN BD} \times \sqrt{2} = 207 \times 1.414 = 293)$$

$$\text{GRAVITY FORCE ON COLUMNS} = 822^k \div 4 = \underline{-206 \text{ KIPS}}$$

$$\text{COLUMN DESIGN: } -293 - 206 = \underline{-499 \text{ KIPS (COMPR.)}}$$

$$\text{UPLIFT: } +293 - 0.85(206) = \underline{116 \text{ KIPS (UPLIFT)}}$$

**DESIGN ANCHOR BOLTS AND FOUNDATION FOR 116 KIPS UPLIFT FORCE**

**\*REFER TO SEAOC 1H16**

Figure F-1. Continued.


DESIGN EXAMPLE: F-2

VERTICAL TANK (ON GROUND)

Description of Structure. A cylindrical water tank on grade with a radius of 10 feet ( $R = 10$ ), a height of 12 feet ( $h_r = 12$ ), and a water depth of 10 feet ( $h = 10$ ). The tank is located in Seismic Zone 4 and  $I = 1.0$ . The weight of the tank is 20 kips.

Required. The period of the sloshing water, the maximum vertical displacement of the water ( $d_{max}$ ), and the design seismic forces.  
Refer to Chapter 13, paragraph 13-4.

Figure F-2. Vertical tank (on ground).



GENERAL

$Z = 0.4$ , SEISMIC ZONE 4

$I = 1.0$

$R_w = 4$  (SEIAC TABLE 1-I)

$C = 1.25 S/T^{2/3} \leq 2.75$  SEIAC EQ 1.2

$S = 1.5$  (NOT KNOWN, SEIAC TABLE 1-B)

$K = h/R = 10.0/10.0 = 1.0$

$W(\text{WATER}) = \pi (10)^2 (10) (0.0624) = 196 \text{ K}$

$W_r(\text{ROOF}) = 0$  (NO ROOF)

$W_w(\text{TANK WALLS}) = 20 \text{ K}$

Figure F-2. Continued.

RIGID BODY FORCES [PARA. 13-4a(1)]

$$V_{RB} = ZIC/R_w (W_r + W_w + W_i) \quad (13-1)$$

$$C = 2.75$$

$$ZIC/R_w = 0.4 \times 1.0 \times 2.75/4 = 0.28$$

$$\begin{aligned} W_i &= 0.54 W \text{ (FOR } \alpha = 1.0) && \text{(TABLE 13-1)} \\ &= 0.54 \times 196 = 106 \text{ K} \end{aligned}$$

$$V_{RB} = 0.28 (0 + 20 + 106) = \underline{35.3 \text{ K}}$$

$$\begin{aligned} h_i &= 0.38 h && \text{(TABLE 13-2)} \\ &= 0.38 \times 10 = 3.8 \text{ FT.} \end{aligned}$$

$$\begin{aligned} h_i' &= 0.80 h && \text{(TABLE 13-2)} \\ &= 0.80 \times 10 = 8.0 \text{ FT} \end{aligned}$$

$$\begin{aligned} M_{RB}(\text{TANK SHELL}) &= ZIC/R_w [W_r h_r + W_w \bar{h}_w + W_i h_i] \quad (13-2) \\ &= 0.28 [0 + 20 (\frac{12}{2}) + 106 (3.8)] \\ &= \underline{146 \text{ K-FT}} \end{aligned}$$

$$\begin{aligned} M_{RB}(\text{BELOW BASE}) &= 0.28 [0 + 20 (\frac{12}{2}) + 106 (8.0)] \\ &= \underline{271 \text{ K-FT}} \end{aligned}$$

Figure F-2. Continued.

# SLOSHING WATER FORCE [PARA. 13-4a (1)]

$$\text{PERIOD, } T = k_T \sqrt{h} \quad (13-4)$$

$$k_T = 0.84 \quad (\text{TABLE 13-3})$$

$$T = 0.84 \sqrt{10} = \underline{\underline{2.66 \text{ SEC.}}}$$

$$V_{SL} = (ZIC/R_w) W_c \quad (13-3)$$

$$C = 1.25 S/T^{1/2} = 0.97$$

$$S = 1.5 \text{ (MAXIMUM VALUE)}$$

$$ZIC/R_w = 0.4 \times 1 \times 0.97 \times 1/4 = 0.097$$

$$W_c = 0.43 W \quad (\text{TABLE 13-1})$$

$$= 0.43 \times 196 = 84.3 K$$

$$V_{SL} = 0.097 \times 84.3 = \underline{\underline{8.2 K}}$$

$$h_c = 0.60 h = 0.60 \times 10 = 6.0 \text{ FT.} \quad (\text{TABLE 13-2})$$

$$h'_c = 0.79 h = 0.79 \times 10 = 7.9 \text{ FT.}$$

$$M_{SL} \text{ (TANK SHELL)} = (ZIC/R_w) W_c h_c \quad (13-5)$$

$$= 0.097 \times 84.3 \times 6.0$$

$$= \underline{\underline{49.1 K-FT}}$$

$$M_{SL} \text{ (BELOW BASE)} = 0.097 \times 84.3 \times 7.9$$

$$= \underline{\underline{64.6 K-FT}}$$

Figure F-2. Continued.

HEIGHT OF SLOSHING WATER

$$\begin{aligned}
 d_{\text{MAX}} &= \left[ \frac{0.75 (Z_{IC}/R_w)}{1 - K_d (Z_{IC}/R_w)} \right] R & (13-6) \\
 &= \left[ \frac{0.75 (0.097)}{1 - (1.75)(0.097)} \right] 10.0 & (K_d \text{ FROM TABLE 13-4}) \\
 &= \underline{\underline{0.88 \text{ FT.}}} & (\text{LESS THAN } h_r - h = 2 \text{ FT, OK})
 \end{aligned}$$

TOTAL DESIGN FORCES [PARA. 13-4a(3)]

$$\begin{aligned}
 V_{\text{TOTAL}} &= \sqrt{V_{RB}^2 + V_{SL}^2} & (13-8) \\
 &= \sqrt{(35.3)^2 + (8.2)^2} = \underline{\underline{36.2 \text{ K}}}
 \end{aligned}$$

$$M_{\text{TOTAL}} = \sqrt{M_{RB}^2 + M_{SL}^2} \quad (13-9)$$

$$\text{FOR TANK SHELL} = \sqrt{146^2 + 49.1} = \underline{\underline{154 \text{ K-FT}}}$$

$$\text{FOR BELOW BASE} = \sqrt{271^2 + 64.6^2} = \underline{\underline{279 \text{ K-FT}}}$$

Figure F-2. Continued.

DESIGN EXAMPLE: F-3

HORIZONTAL TANK (ON GROUND):

Description of Structure. A 20,000 gallon steel tank in concrete saddles on a concrete slab on grade. Seismic Zone 2A,  $I = 1.0$ ,  $S = 1.5$ . For this rigid structure  $T \leq 0.3$  sec.

Lateral Loads:

$$V = \frac{ZIC}{R_w} W$$

where  $Z = 0.15$ ,  $I = 1.0$ ,  $R_w = 4$ ,  $S = 1.5$

$C = 2.75$

$W$  = Weight of Tank plus contents.

(Table 4-1)


$$V = \frac{0.15(1.0)(2.75)}{4} W$$

$$= 0.10 W > 0.075 W \quad (\text{OK})$$

[MINIMUM  $C/R_w = 0.5$ ;  $V = 0.15 \times 0.5W = 0.075W$  (SEAOC 115a)]

*Figure F-3. Horizontal tank (on ground).*





20,000 GALLON TANK  
11'-0" DIAM. x 28'-0" LONG  
WEIGHT TANK PLUS  
CONTENTS 200,000 LBS.  
SEISMIC LATERAL FORCE  
 $V = 0.10 W$   
 $= 0.10 \times 200,000$   
 $= 20,000 \text{ LB.}$   
OR 10,000 LB. EA. SADDLE

### STRAP DESIGN:

FOR THE PURPOSE OF THIS EXAMPLE ASSUME THE REACTION IS AT LEVEL "A" AND NEGLECT WEIGHT OF TANK AND CONTENTS.

$$M = 10,000 \times 4.25 = 42,500' \text{ #}$$

$$\text{STRESS} = 42,500 / 9.0 = 4,720' \text{ # IN STRAP.}$$

### SADDLE DESIGN

FOR REINFORCEMENT ASSUME THE LOAD ON THE PIER TO BE APPLIED AT LEVEL "B"

MOMENT WITH LOAD APPLIED AT LEVEL B

$$M = 10,000 \times 2.5 = 25,000' \text{ # DESIGN REINF. TO RESIST THIS BENDING MOMENT IN ACCORDANCE WITH STANDARD PROCEDURE.}$$

### BASE DESIGN

$$\text{TOTAL O.T.M.} = 20,000 \times 8.5 = 170,000' \text{ #}$$

$$\text{BASE } 12'-6" \times 24'-0" \quad A = 12.5 \times 24 = 300' \text{ #}$$

$$\text{SECTION MODULUS } S = \frac{24 \times (12.5)^2}{6} = 625$$

$$\text{EA. SADDLE} = 5880' \times 2 = 11,760' \text{ #}$$

$$\text{BASE WEIGHT} = 225 \times 300 = 67,500' \text{ #}$$

$$+ 200,000$$

$$279,260' \text{ # TOTAL WEIGHT}$$

$$\frac{P}{A} = \frac{279,260}{300} = 930.87 \quad \frac{M}{S} = \frac{170,000}{625} = 272$$





Figure F-3. Continued.



OVERTURNING ON SUPPORT IS NEGLIGIBLE AND IS NOT INCLUDED IN THIS CALCULATION

#### SADDLE DESIGN

$M_A < M_B$  ABOUT BASE OF TANK =  $10,000 \times 1.25 = 12,500 \text{ lb-ft}$

ABOUT FOOTING =  $10,000 \times 2.75 = 27,500 \text{ lb-ft}$

DESIGN REINF. TO RESIST THESE BENDING MOMENTS IN ACCORDANCE WITH STANDARD PROCEDURE


#### BASE DESIGN

DESIGN REINF. IN FOOTING IN ACCORDANCE WITH STANDARD PROCEDURE TO RESIST SADDLE  $M = 27,500 \text{ lb-ft}$

TOTAL O.T.M. =  $20,000 \times 8.5 = 170,000 \text{ lb-ft}$


SECTION MODULUS  $S = \frac{12.5 \times (24)^2}{6} = 1200$

$\frac{P}{A} = 930.87$  (FROM SHEET 2 OF 3)  $\frac{M}{S} = \frac{170,000}{1200} = 142$



RESULTANT IS IN MIDDLE THIRD  
DESIGN FOOTING FOR SOIL  
PRESSURES SHOWN IN ACCORD-  
ANCE WITH STANDARD  
PROCEDURE.

Figure F-3. Continued.



### GIVEN:

WT. TRANSFORMERS = 3.0 KIPS/EA.  
WT. POLES = 35 LB/FT./POLE  
 $E$  (POLES) =  $1.6 \times 10^6$  LB/IN.<sup>2</sup>  
SOIL PROPERTIES ARE UNKNOWN  
ASSUME EACH POLE ACTS AS A  
20' LONG CANTILEVER  
SEISMIC ZONE 3 OCCUPANCY CATEGORY 1  
(ESSENTIAL FACILITY).

### REQUIRED:

FIND THE SEISMIC FORCE  
COEFFICIENT FOR THE WEAK  
AXIS OF THE POLE FRAME.  
(I.E., NORMAL TO THE PAPER.)

CLASSIFY AS A NON-BUILDING STRUCTURE.

$$T = 0.32 \sqrt{\frac{W}{k}} \quad (\text{EQ 12-1})$$

$$W = 3000 + \frac{35 \times 20}{2} = 3,350 \text{ LB/POLE}$$

CALCULATION OF  $k$ :

$$I_0 (\text{ONE POLE}) = .785 R^4 = .785 (6)^4 = 1017 \text{ IN.}^4$$

$$\Delta = \frac{PL^3}{3EI_0} \quad \text{OR} \quad k = \frac{3EI_0}{L^3} = \frac{3(1.6 \times 10^6)(1017)}{(20 \times 12)^3} = 353 \text{ LBS/IN.}$$

$$\therefore T = 0.32 \sqrt{\frac{3350}{353}} = 0.99 \text{ SEC.}$$

$$V = (ZIC/R_w)W \quad (\text{SEAOC EQ 1-1})$$

$$Z = 0.30 (\text{ZONE 3})$$

$$I = 1.25 (\text{ESSENTIAL FACILITY})$$

$$R = 3 (\text{INVERTED PENDULUM}) \text{ SEAOC TABLE 1-I}$$

$$C = 1.88 (\text{TABLE 4-1 FOR } T = 1.0 \text{ SEC})$$


$$C/R_w = 1.88/3 = 0.63 > 0.50 (\text{SEAOC 115a})$$

$$V = (0.30 \times 1.25 \times 1.88/3)W = \underline{\underline{0.236W}}$$

Figure F-4. Pole-mounted transformer.

**GIVEN :**

MISSILE TRACKING DEVICE SITUATED  
ON TRUSS TOWER: SEISMIC ZONE 2B  
ESSENTIAL FACILITY  
SITE TYPE  $S_3$




**REQUIRED :**

FIND THE LATERAL SEISMIC FORCE TO BE  
APPLIED AT THE CENTER OF GRAVITY OF THE  
TRACKING DEVICE. CLASSIFY AS RIGID  
EQUIPMENT ON A STRUCTURE OTHER THAN A  
BUILDING.

Figure F-5. Tower-mounted equipment.

# SOLUTION :

MEM- BER	P FORCE (KIPS)	L (IN.)	A (IN. <sup>2</sup> )	$\frac{P^2 L}{A}$
AB	1.00	48	$\infty$	0
AC	0	145	2.5	0
AD	0	156	1.0	0
BC	+2.17	156	1.0	734.6
BD	-2.02	145	2.5	236.2
CD	-0.67	72	1.5	21.5
CE	+2.02	145	2.5	236.6
CF	0	167	1.0	0
DE	+1.16	167	1.0	224.7
DF	-3.02	145	2.5	529.0
EF	-0.50	96	1.5	16.0
EG	+3.02	145	2.5	529.0
EH	0	180	1.0	0
FG	+0.75	180	1.0	101.8
FH	-3.63	145	2.5	764.3
GH	+0.30	120	1.5	7.2



NOTE: PT. H IS ASSUMED TO  
TAKE NO BASE SHEAR  
AS MEMBER EH CARRIES  
NO LOAD

$$1K \cdot \frac{\Delta}{2} = \sum \frac{P^2 L}{2AE} ; \sum \frac{P^2 L}{A} = 3401.3 K^2/IN.$$

$$\sum \frac{P^2 L}{AE} = 1.17 \times 10^{-1} = 0.117 \text{ INCHES/KIP}$$

$$\left(\frac{1}{\Delta}\right) = k \quad k = 8.55 \text{ KIPS/IN. PER SIDE}$$

$$T = 0.32 \sqrt{\frac{W}{k}} = 0.32 \sqrt{\frac{8.0}{2(8.55)}} = 0.22 \text{ SEC (EQ 12-1)}$$

$$Z = 0.20 \text{ (ZONE 2B)}, I = 1.25 \text{ (ESSENTIAL FACILITY)}$$

$$R_w = 3.0 \text{ (INVERTED PENDULUM)}, C = 2.75 \text{ (TABLE 4-1)}$$

$$V = (ZIC/R_w)W = (0.20 \times 1.25 \times 2.75/3)W = 0.23 \times 8 = 1.84 \text{ KIPS}$$

NOTE: WEIGHT OF TOWER WAS NEGLECTED.

Figure F-5. Continued.